




# Synergy Telecom P Ltd.

Name	Solar connectors	Model	RO-1 (MC4)
<div data-bbox="167 884 566 1265"></div> <div data-bbox="774 761 1053 1153"><p data-bbox="699 1198 742 1220">RO-1</p></div> <div data-bbox="1173 828 1364 1131"></div>			

# MC4 Solar Connector

Sl No.	Description	Details of MC4
1	MODEL NO.	RO-1
2	Rated Voltage	1500V
3	Rated Current	30A
4	Rated Impulse Voltage	1600V
5	Rated Test Voltage	6KV(50Hz,1Min)
6	RMS Withstand Voltage	8000V
7	Contact Resistance	≤ 0.3mΩ
8	Conductor	Tin plating copper
9	Operating Temperature	-40°C~+85°C
10	Max. Operating Temperature	100°C
11	Degree of Protection	IP67
12	Fire Protection Class	UL94-V0
13	Application Class	Class A
14	Safety Class	Class II
15	Pollution Degree	I
16	Overvoltage Category	I
17	Flame Class	UL94-V0
18	Conductor Cross Section	φ2.5~10.0mm
19	Specify outer wire dia.	2.5~6.0mm <sup>2</sup> AWG14/12/8
20	Insulation Material	Polycarbonate (PC)
21	Sealing Material	Silicon
22	Locking Mechanism	Insert
23	Type of termination	Copper, Tin plated
24	Stripping Length	28.05mm
25	Insertion and Withdrawal Force	Insertion force: ≤50N; Withdarawal force: 300N
26	No of Bending	10000
27	No of engagement cycles	10000
28	Certification	TUV
29	<b>SAMPLES &amp; DOCUMENTS</b>	YES
30	TUV/UL Certificates	TUV
31	Drawing	Can provide
32	Samples for Physically check	Can provide

  
 For Synergy Telecom Pvt. Ltd.  
 Authorised Signatory

**WZ-47 BUDHELLA VILLAGE, VIKASPURI, NEW DELHI – 110018**  
**PHONE: 011-28533349, MOB: 9810138894/9212558066, FAX: 011-28533349**  
**EMAIL: [info@rfconnector.in](mailto:info@rfconnector.in), WEBSITE: <http://rfconnector.in/>**